



ELECTRICAL TESTING LABORATORY

Nexans Network Solutions N.V. – Div. EUROMOLD
ZUID III, Industrielaan 12
B-9320 EREMBODEGEM (AALST)

TEST CERTIFICATE



The test results of the performed test series are given in the test report
No. TE 213 07 10 from ELAB

Requestor:	Nexans Network Solutions n.v. – Div. EUROMOLD Zuid III – Industrielaan 12 B – 9320 Erembodegem
TEST OBJECT TYPE	: Separable Tee connector – interface C : P440TB/G
Rated voltage U_0/U	: 20.8/36 kV
Highest system voltage U_m	: 42 kV
Rated current	: 1250A
Manufacturer	: Nexans Network Solutions n.v. – Div. EUROMOLD
Cable reference	: 1x630 mm ² / 20 – Al – 20.8/36 (42) kV
Request number	: TRF 2007-08c

Start and end date	Test specification
16/03/07 – 16/05/07	CENELEC HD 629.1 S2 (02/2006) Test requirements CENELEC EN IEC61442 (03/2005) Test methods Test series: Table 7 Test sequence D1

TEST RESULT: the test object successfully passed the prescribed test series.

ELAB

Lab. Technician Approval  J. Cauwel	Techn. Responsible – Lab. Responsible Approval  ing. E. De Ridder
--	---

Erembodegem, June 25, 2007